

**Drinking Water Well MTBE Sample History**  
**7-Eleven Store No. 22281**  
**2400 Pleasantville Road**

<b>Sample Date</b>	<b>MTBE Result (ppb) Untreated Water</b>		<b>MTBE Result (ppb) Treated Water</b>
05/17/2006	16		ND
04/12/2006	13		ND
03/12/2006	13	W	ND
02/14/2006	12	A	ND
01/16/2006	16	T	ND
12/15/2005	18	E	ND
11/15/2005	14	R	ND
10/11/2005	23		ND
09/14/2005	12	T	ND
08/10/2005	19	R	ND
07/06/2005	17	E	ND
**06/03/2005	21	A	ND
04/28/2005	22	T	ND
03/10/2005	24	M	ND
*02/10/2005	26	E	ND
12/16/2004	41	N	ND
11/18/2004	18	T	ND
10/21/2004	30		ND
09/22/2004	22		ND
08/23/2004	26		ND

ND – not detected above laboratory detection limits

MTBE – methyl-t-butyl ether  
ppb – parts-per-billion

\* - January 2005 samples not collected because Harford County Health Department reduced sampling frequency from monthly to quarterly; however, 7-Eleven resumed monthly sampling to ensure quality of drinking water.

\*\*– May 2005 samples not collected because system was being serviced.

Samples collected from 7-Eleven's drinking water well treatment system since 2004. Treatment consists of granular activated carbon (GAC) for removal of volatile organic compounds (VOCs) including MTBE.

Samples analyzed at Maryland Spectral Services, Inc., in Baltimore, MD.